



ECONOMIC, ENERGY, AND ENVIRONMENTAL BENEFITS OF BOILER OPTIMIZATION USING THE SEI ACOUSTIC PYROMETER

SUMMARY REPORT

May 2007

Joan L. Pellegrino,
Tracy M. Carole and
Sabine Brueske
Energetics Incorporated

Prepared for
Scientific Environmental Instruments, Inc.
Sparks, NV. 89431
1-800-879-9511
www.sciengr.com

INTRODUCTION

Boilers account for approximately 6,500 trillion Btu or about 37% of all industrial energy use (excluding electricity) in the United States. Coal and natural gas boilers are also used extensively in power generation, with more than 1500 boilers providing more than 500 million Btu per hour of steam. As fuel prices have increased drastically over the past few years, industrial facilities and utilities are seeking low-cost ways to improve energy management and reduce energy costs. Boilers represent a key energy and cost savings opportunity – an increase in boiler fuel efficiency of a few percent can have a significant impact on a facility's boiler operating costs. The BOILERWATCH® MMP-II Acoustic Pyrometer (AP) System developed by Scientific Environmental Instruments Inc. (SEI) can help boiler operators increase boiler efficiency while helping to extend the life of the boiler.

U.S. BOILER POPULATION

An inventory of industrial and electric power generation (utility) boilers in the U.S. is shown in Table 1; the number of boilers is broken down by boiler size category. The total boiler capacity for each size category is summarized in Table 2 [1] [6].

| TABLE 1. U.S. BOILER INVENTORY (NUMBER OF UNITS) | | | | | | | | |
|--|---------------|--------------|---------------|--------------|--------------|---------------|----------------|--|
| MM Btu/hr ^a | Industry | | | | | | | Electric Power Generation ^b |
| | Food | Paper | Chemicals | Refining | Metals | Other Mfg | Industry Total | |
| <10 | 6,570 | 820 | 6,720 | 260 | 1,850 | 7,275 | 23,495 | 37 |
| 10-50 | 3,070 | 1,080 | 3,370 | 260 | 920 | 3,680 | 12,380 | 90 |
| 50-100 | 570 | 530 | 950 | 260 | 330 | 930 | 3,570 | 203 |
| 100-250 | 330 | 540 | 590 | 200 | 110 | 440 | 2,210 | 660 |
| 250-500 | 70 | 490 | 350 | 220 | 120 | 110 | 1,360 | 593 |
| 500-1,000 | | | | | | | | 586 |
| 1,000-5,000 | | | | | | | | 824 |
| 5,000+ | | | | | | | | 210 |
| Total | 10,610 | 3,460 | 11,980 | 1,200 | 3,330 | 12,435 | 43,015 | 3,203 |

a Million Btu per hour

b excluding boilers with 0 load hours

| TABLE 2. U.S. BOILER INVENTORY (TOTAL BOILER CAPACITY, MM BTU/HR) | | | | | | | | |
|---|----------------|----------------|----------------|----------------|----------------|----------------|------------------|---------------------------|
| MM Btu/hr | Industry | | | | | | | Electric Power Generation |
| | Food | Paper | Chemicals | Refining | Metals | Other Mfg | Industry Total | |
| <10 | 31,070 | 4,105 | 28,660 | 1,255 | 7,505 | 29,710 | 102,305 | 161 |
| 10-50 | 64,970 | 24,490 | 81,690 | 6,670 | 19,405 | 80,585 | 277,810 | 2,795 |
| 50-100 | 37,885 | 36,665 | 64,970 | 18,390 | 22,585 | 62,630 | 243,125 | 15,864 |
| 100-250 | 47,950 | 81,500 | 8,640 | 30,480 | 17,775 | 62,790 | 249,135 | 110,501 |
| 250-500 | 27,860 | 229,590 | 150,915 | 114,720 | 45,365 | 47,760 | 616,210 | 212,847 |
| 500-1,000 | | | | | | | | 416,669 |
| 1,000-5,000 | | | | | | | | 1,868,427 |
| 5,000+ | | | | | | | | 2,062,855 |
| Total | 209,735 | 376,350 | 334,875 | 171,515 | 112,635 | 283,475 | 1,488,585 | 4,690,119 |

This analysis uses data from an SEI Acoustic Pyrometer system installation in Mexico and the Energetics Incorporated *Technology Energy and Cost Estimation* model to create an energy, cost, and emissions savings profile of a typical industrial boiler in the U.S. power generation industry. As shown in Tables 1–2, boiler capacity can vary widely. To capture a range of operating characteristics, three typical industrial boiler sizes are included in the analysis: 50 MMBtu/hr, 100 MMBtu/hr, and 250 MMBtu/hr. A typical industrial boiler is assumed to operate 330 days per year and consume a 50/50 mix of natural gas and by-product fuel (fuel gas or refinery gas) [1].

We have included a typical 3,000 MMBtu/hr coal-fired power generation boiler in the analysis to show the relative impact between industrial and utility boilers.

SUMMARY OF SEI DATA AND KEY ANALYSIS ASSUMPTIONS

The data in Table 3 was provided by SEI from installation of an AP system on a 5,000 MMBtu/hr (500 MW) power generation boiler in Salamanca, Mexico, firing a combination of fuel oil and natural gas. The November data represents the base case without AP, and the December data represents the optimized case with AP.

| TABLE 3. ANALYSIS OF SALAMANCA INSTALLATION DATA | |
|---|--|
| Acoustic Pyrometer (AP) System Costs | |
| Initial Cost of BOILERWATCH® MMP-II Acoustic Pyrometer System | \$89,000 |
| Acoustic Pyrometer (AP) System Installation | \$31,500 |
| Salamanca Boiler System | |
| Boiler Description | Borsig boiler, 20 fuel oil / natural gas burners (front and rear walls) |
| Steam Flow | 210,100 lb/hr |
| Steam Pressure | 2,631 psia |
| Steam Temperature | 1004°F |
| Salamanca Energy Data | |
| Boiler Base Case, w/out AP (November 7, 2006 data) | |
| Average Fuel Oil Input | 97,114 lb/hr |
| Average Natural Gas Input | 21,214 lb/hr |
| Average Steam Output ^a | 32,215,295 lb/hr |
| Boiler Optimized Case, w/ AP (December 4 – 9, 2006 data) | |
| Average Fuel Oil Input | 97,339 lb/hr |
| Average Natural Gas Input | 20,521 lb/hr |
| Average Steam Output ^a | 32,693,390 lb/hr |

^a It is assumed that this is on a per hour basis. Note that the average steam output values under energy data significantly differ from the steam flow value under boiler system. This was not explained by SEI personnel, but does not affect the analysis calculations.

The energy data in Table 4 were adjusted so that the optimized case energy data (fuel oil and natural gas) were on the same average steam out level as the base case (see Table 4). This provided a consistent basis to calculate actual energy savings.

| TABLE 4. ADJUSTED ENERGY DATA | |
|---|---------------|
| Energy Data^a | |
| Base Case | |
| Average Energy Input (MMBtu/hr) | 2,430 |
| Average Steam Energy Output (MMBtu/hr) ^b | 32,148 |
| Optimized Case | |
| Average Energy Input (MMBtu/hr) | 2,382 |
| Average Steam Output (MMBtu/hr) | 32,148 |

a MMBtu/hr = million Btu per hour

b Conversion assumes 1,000 Btu/lb steam

As the data in Table 4 shows, the use of the AP system resulted in a 2% decrease in fuel consumption. This value, along with the AP system cost data in Table 3 were used as inputs to the Energetics energy and economics estimating model. Note that since the boiler capacity is defined as the fuel input, the boiler efficiencies for the three boiler capacities are not necessary for the analysis. Key financial assumptions, including energy prices for three scenarios (business-as-usual, high, and low) are shown in Table 5. For by-product fuel the price is assumed to be zero.

| TABLE 5. KEY FINANCIAL ASSUMPTIONS | |
|--|--------|
| Discount Rate | 10% |
| Inflation Rate per Year | 2% |
| Equipment Lifetime (Years) | 10 |
| Natural Gas Prices (\$/MMBtu) ^a | |
| Business-As-Usual | \$6.81 |
| High | \$8.75 |
| Low | \$5.35 |

a Based on historical (since 2003) and projected U.S. industrial natural gas prices [2,3]. Fuel prices are assumed steady for the 5-year energy projections in the results section.

ANALYSIS RESULTS

The economic, energy, and environmental benefits resulting from implementation of the SEI acoustic pyrometer system on a 50, 100, and 250 MMBtu/hr industrial boiler are shown in Table 6 along with the benefits for a typical 3,000 MMBtu/hr coal fired power generation boiler, similar to the Salamanca installation presented in Table 3.

Energy, cost, and emissions savings are projected out to five years for the four boiler examples in Figures 2, 3, and 4.

**TABLE 6. ECONOMIC, ENERGY, AND ENVIRONMENTAL BENEFITS OF BOILERS
OPERATING WITH THE SEI ACOUSTIC PYROMETER SYSTEM^a**

| | Industry | | | Electric Power Generation ^g |
|---|------------------|----------|-----------|---|
| Boiler Capacity (MMBtu/hr) ^d | 50 | 100 | 250 | 3,000 |
| Annual Energy Savings (Billion Btu/year) | 7.9 | 15.8 | 39.4 | 236.5 |
| Annual Energy Cost Savings (\$/year) | | | | |
| Business-As-Usual Case | \$26,845 | \$53,690 | \$134,225 | \$369,000 |
| High Natural Gas Price Case | \$34,493 | \$68,985 | \$172,463 | |
| Low Natural Gas Price Case | \$21,090 | \$42,179 | \$105,449 | |
| Annual Rate of Return (%) ^c | | | | |
| Business-As-Usual Case | 22 | 44 | 111 | 303 |
| High Natural Gas Price Case | 28 | 57 | 142 | |
| Low Natural Gas Price Case | 17 | 35 | 87 | |
| Discounted Payback Period (years) | | | | |
| Business-As-Usual Case | 6.9 | 2.8 | 1.0 | 0.36 |
| High Natural Gas Price Case | 4.9 | 2.1 | 0.8 | |
| Low Natural Gas Price Case | >10 ^d | 3.8 | 1.3 | |
| Annual Emissions Reductions ^e | | | | |
| CO ₂ (MTCE/year) ^f | 124 | 248 | 621 | 5,990 |
| NO _x (lb/year) | 1,838 | 3,676 | 9,189 | 132,167 |
| Particulates (lb/year) | 3 | 7 | 17 | 6,296 |
| VOC (lb/year) | 50 | 101 | 251 | 676 |

a All financial analysis results are before-tax values.

b Analysis assumes that boilers operate 330 days per year at full capacity.

c Does not include the discount rate.

d Payback period is greater than the assumed technology lifetime.

e Emission coefficients from the U.S. Environmental Protection Agency and U.S. Department of Energy [4,5].

f Metric tons carbon equivalent.

g Electric power generation analysis is based on bituminous coal fuel at a business-as-usual price of \$37.51 per short ton and an average heating value of 24 MMBtu/ton [7].




Figure 1. Cumulative Energy Savings (Billion Btu)




Figure 2. Cumulative Carbon Dioxide Reduction (Metric Tonnes Carbon Equivalent Btu)




Figure 3. Cumulative Cost Savings for Four Boiler Scenarios (business as usual fuel prices)

CONCLUSIONS

Paybacks based on energy cost savings are very attractive for boilers using the AP system. Key conclusions:

- Paybacks are most attractive for larger boiler sizes (≥ 100 MMBtu/hour steam output). An AP system application in a 250 MMBtu/hr boiler can be expected to achieve \$134,000 in energy cost savings per year. A mid-size 100 MMBtu/hr boiler can be expected to achieve over \$54,000 per year in energy cost savings (business-as-usual natural gas prices).
- Smaller boiler systems (50 MM Btu/hour or less) may not find the AP system economically attractive, except in very high natural gas price scenarios
- By applying the same energy and economics model to a large power generation boiler with AP system installed, the potential energy cost savings are shown to be as high as \$369,000 per year for the 3,000 MMBtu/hr coal fired boiler example.
- Emissions of NO_x are reduced along with use of natural gas; the system also reduces emissions of carbon dioxide, a primary greenhouse gas.

REFERENCES

1. Energy and Environmental Analysis, Inc., *Characterization of the U.S. Industrial Commercial Boiler Population*, May 2005.
2. "U.S. Natural Gas Industrial Price (Dollars per Thousand Cubic Feet)," Natural Gas Navigator, U.S. Department of Energy, Energy Information Administration, updated February 9, 2007.
3. *Annual Energy Outlook 2007 with Projections to 2030*, U.S. Department of Energy, Energy Information Administration, February 2007.
4. *AP 42, Compilation of Air Pollutant Emissions Factors Volume I: Stationary Point and Area Sources, 5th Edition*, U.S. Environmental Protection Agency.
5. *Emissions of Greenhouse Gases in the United States 2005*, U.S. Department of Energy, Energy Information Administration, November 2006.
6. *Emissions & Generation Resource Integrated Database, eGRID*, Version 2.1, updated April 30, 2007, U.S. Environmental Protection Agency.
7. *Annual Energy Review 2005*, U.S. Department of Energy, Energy Information Administration, Table 7.8, Coal Prices for 2005 and Glossary.